

# Characterization of Uncertainty Contributions in a High-Accuracy PMU Validation System

Guglielmo Frigo, Asja Derviškadić, Daniele Colangelo, Jean-Pierre Braun and Mario Paolone

**Abstract**—The effective deployment of Phasor Measurement Units (PMUs) in Distribution Networks (DNs) requires an enhancement in terms of estimation accuracy beyond the limits of IEEE Std C37.118.1 (IEEE Std), aiming at a Total Vector Error (TVE) in the order of 0.0x% in steady-state test conditions. As a consequence, a rigorous metrological characterization of PMU performance requires a validation system whose accuracy is at least one order of magnitude better than the one of the device under test, i.e. it requires a TVE in the order of 0.00x% in steady-state test conditions and 0.0x% in distorted or dynamic test conditions. In this paper, we describe the hardware and software architecture of a PMU validation system specifically designed for PMUs operating in DNs. We evaluate the quality of the generated test waveforms, and we carry out a thorough metrological characterization of the uncertainty contributions due to generation, acquisition and synchronization stages.

**Index Terms**—Phasor Measurement Unit (PMU); validation; metrological characterization; synchrophasor; IEEE C37.118.1.

## I. INTRODUCTION

Electric distribution systems (DNs) are rapidly evolving from passive to active power infrastructures [1]. To address this issue, the recent literature has discussed the deployment of Phasor Measurement Units (PMUs) also to DN scenario. Indeed, in the presence of distributed renewable energy sources, PMUs could represent an interesting solution for a wide range of applications, like real-time state estimation, power flow monitoring, fault detection, voltage and frequency control [2].

In general, PMUs are measurement devices capable of providing estimates of voltage and current synchrophasors, frequency and Rate-of-Change-of-Frequency (ROCOF) associated to the power signal fundamental component. These estimates are updated with high reporting rates and synchronized with respect to the Coordinated Universal Time (UTC). PMU technology has been originally conceived for monitoring and protection applications in the high-voltage transmission networks (TNs). Accordingly, the related IEEE Std. C37.118.1 [3] and its recent amendment [4], henceforth called IEEE Std, define the requirements in terms of accuracy and latency, with specific reference to TN scenarios.

The uncertainty of PMU estimation is expressed in terms of Total Vector Error (TVE), which accounts for both synchrophasor magnitude and phase, Frequency Error (FE), and

ROCOF Error (RFE). In this context, the IEEE Std requires TVE not to exceed 1%, that corresponds to either a magnitude error of 1% (with null phase error) or a phase error of 1 mrad (at 50 Hz, with null magnitude error).

In view of PMU applications in DNs, this accuracy level proves to be insufficient and unsuitable: the phase difference between adjacent nodes could be comparable with the IEEE Std uncertainty limit [5], and the observed dynamics could be faster and more complex than the ones provided by the IEEE Std compliance tests [6]. Therefore, it is reasonable to say that a definite enhancement in PMU accuracy is not only recommended, but also required for an effective deployment to DNs. In this regard, we can define a more realistic performance requirement as a TVE in the order of 0.x% in steady-state conditions [7]. As regards FE, distributed generation might produce transitory frequency oscillations with a period in the order of some seconds [8]. Accordingly, an accuracy level around hundreds  $\mu\text{Hz}$  would be recommendable in steady-state conditions. As regards RFE, instead, the recent IEEE Std amendment has significantly relaxed the ROCOF accuracy requirements. Nevertheless, based on current ROCOF-based relays, it is reasonable to require an accuracy level around tens mHz/s in steady-state conditions [9].

In the recent years, the literature has proposed many different algorithms for synchrophasor estimation capable of facing that level of accuracy [10]. Nevertheless, in practice, the rigorous metrological characterization of the algorithms' performance still represents an open issue for national metrological institutes, research laboratories and manufacturers.

The compliance certification with respect to the standard requirements has to be performed by comparing the device under test with a reference system whose uncertainty is at least one order of magnitude better. Accordingly, in this case, the PMU validation system must generate test waveforms whose reference synchrophasor, frequency and ROCOF are known with a TVE in the order of 0.0x% [11]. It is worth noticing that, since a reference standard for DNs is still missing, we refer to the developed architecture as validation rather than calibration system. In this regard, the International Vocabulary of Metrology defines validation as the verification process where the device performance is compared with specified requirements that are adequate for an intended use [12].

The collaboration between the Distributed Electrical Systems laboratory at École Polytechnique Fédérale de Lausanne (DESL-EPFL) and the Swiss Federal Institute of Metrology (METAS) aims at the development of a high-accuracy PMU validation system capable to deal with this stringent requirement. In [13] we describe the hardware architecture, whereas

Manuscript received X Month 2018.

Corresponding author's e-mail: [guglielmo.frigo@epfl.ch](mailto:guglielmo.frigo@epfl.ch)

G. Frigo, A. Derviškadić and M. Paolone are with École Polytechnique Fédérale de Lausanne, 1015 Lausanne, Switzerland.

D. Colangelo is with DNV GL, Arnhem, Netherlands.

J.-P. Braun is with Federal Institute of Metrology (METAS), Bern-Wabern, Switzerland.

in [14] we thoroughly characterize the software routine used to define the reference synchrophasors, frequency and ROCOF. In [17] we characterize the uncertainty contribution due to the voltage amplifier stage and evaluate their frequency response over the expected measurement bandwidth. In the present paper, instead, we focus on the metrological characterization of the hardware uncertainty contributions inherent in the generation, acquisition and synchronization of the test waveforms.

The paper is organized as follows: in Section II, we provide a brief overview of the existing calibration systems and derive the motivations of this work; Section III describes the hardware and software architecture of the proposed PMU validation system; in Section IV we evaluate the power quality of the generated test waveforms and we perform the metrological characterization of magnitude, phase and frequency uncertainty; the performance in the IEEE Std tests is thoroughly reported in Section V in terms of TVE, FE and RFE; in Section VI we discuss the capability of reproducing user-defined test conditions, such as voltage unbalanced waveforms and current inrush events; finally, Section VII provides the closing remarks.

## II. RESEARCH SCENARIO

In general, the hardware architecture of current PMU calibrators is well-established and consists of three main stages: (i) a generation stage that generates the test waveforms and feeds them to the PMUs under test; (ii) an acquisition stage that simultaneously acquires the same test waveforms and processes them in order to define the reference synchrophasor, frequency and ROCOF; (iii) a synchronization stage that triggers both the generation and acquisition stage, and guarantees that the calibrator estimates are aligned to UTC.

The three stages introduce uncertainty in the overall calibration procedure. In this context, the system accuracy depends on the capability of minimizing the uncertainty on synchrophasor magnitude and phase angle introduced by generation and acquisition stages, as well as the timing reference uncertainty inherent in the synchronization stage.

Several versions of PMU calibrators have been recently developed by national metrological institutes [15]–[18], research laboratories [14], [19]–[21] and manufacturing companies [22], [23]. To the best of authors' knowledge, the reference grade is represented by the calibration systems of the National Institute of Standards and Technology (NIST), Washington, DC and of the Swiss Federal Institute of Metrology (METAS), Bern, CH. In fact, they are capable of performing the IEEE Std compliance verification with a TVE in the order of 0.05% in static test conditions and the uncertainty on synchrophasor phase angle is limited to 300  $\mu$ rad.

The motivation of the present paper, in continuation to the work of NIST and METAS, is twofold: (i) the development of a high-accuracy validation system for PMUs operating in ADNs; (ii) the metrological characterization of some uncertainty contributions inherent in modern PMU calibrators, with specific reference to synchrophasor phase angle contributions.




Fig. 1. Hardware architecture of the proposed validation system. Generation (DACs) and acquisition (ADCs) boards are aligned to UTC through the same synchronization board, that is disciplined by a GPS-receiver and a Rubidium atomic clock in order to enhance the stability of the internal time-base.

## III. HARDWARE AND SOFTWARE ARCHITECTURE

### A. Hardware architecture

The hardware architecture of the proposed PMU validation system is shown in Fig. 1 and consists of five main elements. From left to right: (i) the GPS-receiver guarantees the alignment with the absolute time reference; (ii) the rubidium atomic clock enhances the short-term variability of the internal time-base, as shown in Section IV-F; (iii) the time-synchronization board receives from the atomic clock a pulse-per-second (PPS) and a 10 MHz trigger signal and employs them to align the different hardware modules; (iv) the generation board with three digital-to-analog converters (DACs) capable to reproduce three-phase waveforms compliant with IEEE Std specifications; (v) the acquisition board whose analog-to-digital converters (ADCs) re-acquire the waveforms sent to the PMU under test and enable us to extract the reference values of synchrophasor, frequency and ROCOF.

The core of the entire validation system is represented by a NI PXI 1042Q (National Instruments, Austin, TX), supplied with three operating modules: the NI PXI-8110 embedded controller, the NI PXI-6682 synchronization board, and the NI PXI-6289 data acquisition board [24]. The internal trigger is provided by the FS725 rubidium oscillator (Stanford Research Systems, Sunnyvale, CA) [25], disciplined by the GPS 169-PCI Radio Clock (Meinberg, Bad Pyrmont) [26].

The rubidium oscillator provides a reduced short-term variability on the 10 MHz time-base signal, whereas the GPS clock guarantees the alignment with respect to UTC and minimizes the long-term variability (see Section IV for further discussion and experimental validation).

The NI PXI-6289 board enables us to generate and simultaneously re-acquire the three-phase waveforms provided to the PMU under test. In the generation stage, the PMU calibrator employs three 16-bits DACs with an output range of  $\pm 10$  V and a sampling frequency of 100 kHz. The test waveforms are defined according to the IEEE Std specifications, but can also reproduce additional operating conditions, like phase unbalance or in-rush event, typical of ADN scenarios. In the acquisition stage, the three-phase waveforms are digitized by a multiplexed 18-bits ADC with an input range of  $\pm 10$  V and a sampling frequency of 25 kHz. In this regard, it is important to observe that the phase displacement introduced by the multiplexed acquisition has been experimentally characterized

TABLE I  
NL-LSQ PERFORMANCE SUMMARY

Test	TVE [%]
nominal steady-state	$1.68 \cdot 10^{-4}$
noise (SNR = 80 dB)	$7.80 \cdot 10^{-4}$
harm. dist. (THD = 10%)	$1.70 \cdot 10^{-4}$
out-of-band (TIHD = 10%)	$4.02 \cdot 10^{-4}$

and suitably compensated. Any other uncertainty contribution due to internal timing-source is further discussed in Sec. IV-F.

Even though a typical nominal voltage for testing PMUs is 70 Vrms [27], we address this work to innovative DN applications that employ new-generation sensors, characterized by low-voltage outputs, in the order of few tens V [28]–[30]. For this reason, in its actual implementation, the validation system generates voltage signals in the range of  $\pm 10$  V.

The inclusion of voltage amplifiers and dividers within the generation and acquisition stage would allow for increasing the output level, up to the IEEE Std range. However, the accuracy and stability of such devices still represent open issues for power system applications and their uncertainty contributions might largely exceed the target performance [31], [32]. Nevertheless, their frequency response can be carefully characterized and compensated, in order to mitigate the propagation of uncertainty to the final estimation of the reference values [17]. In this paper, instead, we focus on the uncertainty contributions due to the other hardware components, i.e. generation, acquisition and synchronization stages.

### B. Software architecture

A non-linear least-squares (NL-LSQ) fitting algorithm processes the acquired waveform and determines the reference values of synchrophasor, frequency and ROCOF. The choice of this peculiar synchrophasor estimation algorithm is based on its noticeable accuracy, as shown by the performance characterization in [33]<sup>1</sup>. Table I reports the estimation accuracy in terms of TVE in four significant test conditions, like additive Gaussian noise and interference coming from harmonic or inter-harmonic components (the complete performance evaluation in IEEE Std test conditions is provided in Section V). In this regard, it is worth observing that NL-LSQ satisfies the performance requirement of a TVE in the order of 0.0x%.

The proposed validation system implements the mathematical model of a generic time-variant noise-less power signal affected by disturbances, defined as follows:

$$x(t) = A(1 + \varepsilon_A(t)) \cdot \cos(2\pi ft + \varphi_0 + \varepsilon_\varphi(t)) + \eta(t) \quad (1)$$

where  $A$ ,  $f$  and  $\varphi_0$  are the amplitude, frequency and initial phase of the fundamental component, respectively,  $\varepsilon_A(t)$  and  $\varepsilon_\varphi(t)$  account for amplitude and phase modulations, and  $\eta(t)$  is the contribution of harmonic or inter-harmonic components or transient events not related to the fundamental component.

<sup>1</sup>The performance discrepancy is due to the fact that in [33] the sampling frequency is equal to 100 kHz, whereas the present configuration adopts a sampling frequency of 25 kHz.

During the validation process, the user sets the parameters in (1) to reproduce the desired test conditions. Then, the system provides the corresponding waveforms to one or more devices under test and simultaneously re-acquires them. Finally, the NL-LSQ algorithm determines the triplet of reference values:

$$\mathcal{P} = \{\hat{A}, \hat{f}, \hat{\varphi}_0\}. \quad (2)$$

Based on these results, we can define the synchrophasor associated to the fundamental component as:

$$X(t) = A_s e^{j\Phi_s}, \quad A_s = \frac{\hat{A}}{\sqrt{2}}, \quad \Phi_s = 2\pi \hat{f}t + \hat{\varphi}_0 \quad (3)$$

where  $A_s$  is equal to the root-mean-squared (RMS) magnitude, and  $\Phi_s$  is the synchrophasor phase angle that accounts for both fundamental frequency and initial phase.

It is worth mentioning that these synchrophasors are specifically time-stamped by the validation system, whilst a phasor data concentrator collects the estimates provided by the PMU(s) under test, and align them based on their time-stamp [35]. In this way, it is possible to compare reference and estimated values associated to the same time-stamp and accordingly determine the accuracy of the devices under test.

In the present analysis, we consider an observation interval of 60 ms, as typically adopted by P-class compliant PMUs. In fact, a longer observation interval cannot satisfy the stringent IEEE Std requirements in terms of reporting latency<sup>2</sup>. In the following metrological characterization, the validation system adopts such observation interval, in order to determine its worst-case performance and guarantee a fair comparison with the devices under test. Nevertheless, the validation system is not subject to restrictions in terms of measurement latency and a higher level of accuracy can be achieved by enlarging the observation interval length, as shown in [33].

The reporting rate can be adapted to the specific test requirements. Indeed, given the signal model and the parameter estimates, it is possible to retrieve the reference value at any desired time instant. This functionality proves to be particularly useful during the step change tests, where the IEEE Std requires to perform an interleaved analysis of the PMU response in terms of TVE and FE.

## IV. METROLOGICAL CHARACTERIZATION IN STEADY-STATE CONDITIONS

In this Section, we provide a rigorous metrological characterization of the test waveform accuracy in terms of magnitude, phase and frequency. Once set the generation parameters, we compare the validation system's estimates with the reference values provided by high-accuracy hardware instrumentation. It should be noticed that the present analysis considers only steady-state test signals, in the absence of interfering tones, as the performance of hardware instrumentation is no more guaranteed otherwise [25], [37], [39]. Nevertheless, it is reasonable to say that similar results are obtained in the other test

<sup>2</sup>Since synchrophasor estimates are typically referred to the observation interval midpoint, four nominal cycles represent the upper limit to keep latency lower than two times the reporting period (in the present case: 40 ms).

conditions, as the generation procedure is exactly the same and does not depend on the model of the test signal.

In this regard, it should be noticed that the test waveforms are computed in LabVIEW based on (1) and the user-defined parameters. DACs reproduce the resulting sequences of finite-precision numbers<sup>3</sup>, that are successively acquired by ADCs. For this reason, these stages can be said independent from the implemented signal model.

For each parameter configuration, we acquire a time-series with an overall duration of 5 s, and divide it into 248 consecutive observation intervals of 60 ms, partially overlapped by 40 ms in order to reproduce a reporting rate equal to 50 fps. Assuming a normal distribution, we describe the discrepancy between estimated and reference values in terms of mean and standard deviation. The first one constitutes a systematic contribution and can be compensated in the system's software, whereas the second one is a random contribution and represents the actual uncertainty of the measurement process. As a consequence, the present characterization focuses only on this last contribution. Since we consider three-phase waveforms, each parameter configuration provides three slightly different uncertainty values. Unless otherwise indicated, in the following graphs, the bold lines determine the confidence interval between the minimum and maximum standard deviations measured on the three phases, whereas the markers represent the average uncertainty of the system.

#### A. Power quality of the generated waveforms

In this subsection, we discuss on the spurious contributions introduced by generation and acquisition stage. First of all, we characterize the uncorrelated noise in terms of signal-to-noise and distortion (SINAD) ratio, and we evaluate the effect of narrow-band components by computing the total harmonic distortion (THD) index over the first 50 harmonics. Secondly, we verify that the generated test waveforms are perfectly balanced three-phases signals.

For this analysis, given the signal model in (1), we consider steady-state test conditions (i.e.  $\varepsilon_A, \varepsilon_\varphi, \eta = 0$ ). We set the amplitude and initial phase equal to 9 V and 0 rad, respectively, and we vary the fundamental frequency from 45 to 55 Hz<sup>4</sup>.

In LabVIEW, we compute the SINAD and THD associated to each observation interval. In particular, once detected the spectrum highest peak, an interpolated DFT algorithm estimates the fundamental frequency and RMS amplitude [34]. In this context, SINAD is defined as the ratio between the fundamental energy and the remainder signal energy, expressed in dB, whereas THD is the ratio between the RMS sum of the harmonic tones (up to 50<sup>th</sup> order) and the RMS amplitude of the fundamental tone. At the same time, we apply the symmetrical components' method to decompose the three-phase signal into its direct, inverse and homopolar sequence. For each 60 ms observation interval, we compute the energy of inverse and homopolar sequences, and normalize them by the energy of corresponding direct sequence.

<sup>3</sup>We adopt the Extended Precision data type: the uncertainty contribution is negligible if compared with generation and acquisition stage ones.

<sup>4</sup>In this paper, we assume a system nominal frequency of 50 Hz, but equivalent results can be obtained in the 60 Hz-scenario.




Fig. 2. Power quality assessment of the generated test waveform in terms of SINAD (top) and THD (bottom) in steady-state test conditions, as function of the fundamental frequency. The cross represents the mean value, whereas the bold line determines a confidence interval of three standard deviations.

In this way, we can infer the distribution of the observed indices in terms of mean value  $\mu$  and standard deviation  $\sigma$ . In Fig. 2 and 3, the markers represent the mean values, whereas the bold lines identify a confidence interval of  $\pm 3\sigma$ .

As shown in Fig. 2, in the considered frequency range, SINAD keeps around 93.4 dB, which corresponds to an equivalent number of 15 bits, whereas THD varies between 4 and  $6.5 \cdot 10^{-4}\%$ . Both these experimental results confirm that the waveforms are affected by nearly negligible levels of additive noise and distortion. In this regard, it should be noticed that the IEEE Std requires THD and possible distortions coming from interfering components not to overcome 0.02% [3].

Fig. 3 quantifies the unbalance ratio associated to inverse (blue) and homopolar (red) sequences, as function of the fundamental frequency. Both these contributions exhibit an energy content in the order of some ppm of the direct sequence, whereas the EN Std. 50160 limits the unbalance ratio to 2%.for distribution networks [36]. Accordingly, it is reasonable to say that the proposed system generates test waveforms that adequately approximate a balanced three-phase grid.

We repeat this power quality analysis in all the test conditions provided by the IEEE Std. In a conservative way, we set the waveform parameters according to the worst-case of M-class compliance requirements. For each test, we measure three performance indices: the aforementioned SINAD ratio to evaluate the incidence of noise and distortion, the spurious free dynamic range (SFDR) to determine the ratio between the RMS amplitude of the fundamental and the highest interfering component, and the voltage unbalance factor (VUF) to




Fig. 3. Energy ratio of inverse (blue) and homopolar (red) sequence with respect to direct sequence, in steady-state test conditions, as function of the fundamental frequency. The cross represents the mean value, whereas the bold line determines a confidence interval of three standard deviations.

TABLE II  
POWER QUALITY INDICES OF GENERATED TEST WAVEFORMS

Test	SINAD [dB]	SFDR [dB]	VUF [ppm]
steady-state	93.38	110.23	1.51
harmonic dist.	20.04	19.96	3.11
out-of-band dist.	20.04	19.94	2.05
meas. bandwidth	93.22	109.88	3.98
frequency ramp	93.34	108.54	4.70
step change	93.33	109.36	2.54

quantify the entity of the indirect sequence.

Table II reports the mean value of the considered indices as function of the test condition. In particular, SINAD ratio keeps unaltered around 93 dB, except for harmonic and out-of-band distortion tests, where SINAD is equal to 20 dB. In fact, these two tests require the presence of an interfering component, whose magnitude is equal to 10% the fundamental magnitude. As regards SFDR, in all the test conditions the index is equal to almost 110 dB, i.e. the noise floor is at least five order of magnitude lower than the fundamental component. Only in the presence of harmonic or out-of-band distortion, SFDR almost reaches 20 dB. Finally, the VUF analysis shows that the mean energy ratio between inverse and direct sequence does not exceed 5 ppm. It is thus reasonable to say that the proposed system satisfies the IEEE Std requirements in terms of power quality of the generated waveforms, in both static and dynamic test conditions.

### B. Magnitude uncertainty

We evaluate the uncertainty on the synchrophasor magnitude by comparing the system estimates with the measurements provided by the 3458A Digital Multimeter (Keysight Technologies, Santa Rosa, CA) with a resolution of 8.5 digits, equal to  $\pm 1 \mu\text{V}$ . In particular, we adopt the AC Voltage modality with synchronous sub-sampling technique. As shown in Fig.




Fig. 4. Measurement setup for the assessment of magnitude uncertainty. The generated waveforms are simultaneously sent to the ADC stage and to the digital multimeter (DVM). The synchronization between the two measurement chains is guaranteed by the same trigger provided by the atomic clock.




Fig. 5. Magnitude uncertainty as function of the fundamental frequency. MU tends to increase as the fundamental frequency decreases. The maximum value is obtained for  $f = 45$  Hz, when MU does not exceed  $12 \mu\text{V}$ .

4, the instrument is triggered by a clock signal derived from the same rubidium atomic clock as the PMU calibrator. We set an input range of  $\pm 10$  V, an acquisition time window of 1 s, and we compute the average over 5 consecutive readings. In this way, we produce a single measurement for each test but we are capable of reducing the effect of time jitter and measurement noise, and guaranteeing an accuracy of 10 ppm in the frequency range from 1 Hz to 10 MHz [37], [38].

For this analysis, we consider a three-phase waveform in steady-state test conditions, and we evaluate the random contribution of synchrophasor magnitude uncertainty, briefly MU, as function of fundamental frequency and magnitude.

In Fig. 5, we set fundamental amplitude and initial phase equal to their nominal values, i.e. 9 V and 0 rad, whereas we vary fundamental frequency from 45 to 55 Hz with an incremental step of 1 Hz. In this range, MU keeps rather stable and does not exceed  $12 \mu\text{V}$ . The accuracy performance slightly degrades, as the fundamental frequency decreases, e.g. 45 Hz. As analysed in [33], this is due to the fact that a lower fundamental frequency corresponds to a lower number of periods in the fixed observation interval of 60 ms, resulting in a degradation of the NL-LSQ accuracy.

Fig. 6 shows the normalized MU as function of the fundamental magnitude. In the signal model (1), we fix the fundamental frequency and initial phase to 50 Hz and 0 rad, respectively, and we consider three amplitude values, namely 9, 4.5 and 0.9 V, that correspond to 100, 50 and 10% of the nominal value. In the considered range, a slight performance




Fig. 6. Normalized magnitude uncertainty as function of the fundamental amplitude. It should be noticed that MU keeps below  $1 \cdot 10^{-4}\%$ , even when  $A$  is decreased up to 10% of the nominal value.




Fig. 7. Measurement setup for the assessment of frequency uncertainty. The generated waveforms are simultaneously sent to the ADC stage and to the counter (DFM). The synchronization between the two measurement chains is guaranteed by the same trigger provided by the atomic clock.

degradation is noticed as the fundamental amplitude decreases. Nevertheless, the percentage error does not exceed  $1 \cdot 10^{-4}\%$ .

### C. Phase uncertainty

Given the synchrophasor model in (3), the phase angle  $\Phi_s$  accounts for both fundamental frequency and initial phase. In this context, a deviation from the nominal system frequency (in our case 50 Hz) produces a rotation of the synchrophasor associated to the fundamental component, and can be interpreted as a contribution to the overall phase angle.

For this reason, in defining the reference values for the generated waveforms, we employ a twofold approach. On one side, we measure the fundamental frequency through the SR620 counter (Stanford Research Systems, Sunnyvale, CA), with an acquisition time window of 1 s, and an accuracy in the order of 10 nHz [39]. As in the previous paragraph, the synchronization between the validation system and the analog instrument is guaranteed by the trigger signal provided by the atomic clock (see Fig. 7). On the other side, we define the ground truth value of fundamental initial phase<sup>5</sup> by processing the acquired three-phase waveform with the Enhanced Interpolated DFT (eIpDFT) algorithm, that is expected to provide an accuracy in the order of hundreds nrad [34].

<sup>5</sup>The counter SR620 cannot provide simultaneous estimates of both frequency and initial phase. Therefore, we need a further measurement procedure to define the reference value for the fundamental initial phase.




Fig. 8. Phase uncertainty as function of the fundamental frequency. A performance degradation is noticed as the fundamental frequency deviates from its nominal value,  $f = 50$  Hz. Nevertheless, in the worst case, PU does not exceed  $0.85 \mu\text{rad}$ .




Fig. 9. Phase uncertainty as function of the fundamental initial phase. In the entire considered range, PU does not exhibit significant variations, between  $0.35$  and  $0.5 \mu\text{rad}$ .

Similarly to the analysis of magnitude uncertainty, the metrological characterization considers a three-phase waveform in steady-state test conditions, and evaluates the random contribution of synchrophasor phase uncertainty, briefly PU, as function of fundamental frequency and initial phase.

In the first case, we fix fundamental amplitude and initial phase to 9 V and 0 rad, respectively, and we vary the fundamental frequency from 45 to 55 Hz, with an incremental step of 1 Hz. As shown in Fig. 8, PU exhibits a rather symmetrical trend: the uncertainty increases as the fundamental frequency deviates from its nominal value, i.e. 50 Hz. In the considered frequency range, the worst-case performance corresponds to a maximum PU of  $0.8 \mu\text{rad}$ .

In the second case, instead, we consider the influence of fundamental initial phase in the range  $[0, \pi]$  rad, with an incremental step of  $\pi/12$  rad. As shown in Fig. 9, PU variations are almost negligible and limited to  $0.5 \mu\text{rad}$ .

### D. Frequency and ROCOF

As further discussed in [33], the proposed validation software assumes the fundamental frequency as a known parameter of the optimization problem solved by the NL-LSQ algorithm. In support of this hypothesis, we assessed the stability of generated waveform frequency over repeated




Fig. 10. Frequency uncertainty as function of the fundamental frequency. A rather symmetric trend is noticed as the fundamental frequency deviates from its nominal value,  $f = 50$  Hz. In the worst case, FU does not exceed  $4.5 \mu\text{Hz}$ .

experiments by means of the SR620 counter. Specifically, we have generated single-tone steady state signals by setting frequencies in the range [45, 55] Hz. We have noticed that the measured frequency deviates from the value set by the user by some tens of nHz, i.e., comparable with the instrument resolution. Based on the selected signal model and user-defined parameters, the system computes the time-series of the test waveform and sends it to the generation stage, where the DACs reproduce the samples in playback mode. Since the internal time-base stability is guaranteed by the atomic clock, it is reasonable to expect that the sampling process does not introduce significant signal distortions.

The frequency associated to the fundamental component can be defined as the first time-derivative of the synchrophasor phase angle. Therefore, based on PU characterization, we can derive the confidence interval for the estimation of fundamental frequency. The synchrophasor phase angle depends on both fundamental frequency and initial phase. In order to provide a more conservative evaluation of this uncertainty contribution, we assume a zero-valued error on the initial phase, and we interpret the entire PU as only frequency uncertainty (FU).

In Fig. 10, we evaluate FU as function of the fundamental frequency. For this analysis, we set amplitude and initial phase equal to 9 V and 0 rad, respectively, and vary the fundamental frequency from 45 to 55 Hz. At 50 Hz, FU is limited to  $2.3 \mu\text{Hz}$ . In the entire range, we notice a rather symmetric trend: the estimation accuracy degrades as the fundamental frequency deviates from its nominal value. The worst-case performance is obtained at 47 Hz, with FU nearly equal to  $4.3 \mu\text{Hz}$ .

The ROCOF uncertainty (RFU) directly descends from FU. Coherently with the IEEE Std formulation, ROCOF is defined as the difference between two consecutive frequency estimates, divided by the reporting time (in our case equal to 20 ms). In this context, the worst-case RFU can be computed as:

$$\text{RFU} = \frac{2 \cdot \text{FU}}{0.02}. \quad (4)$$

In the considered frequency range, the worst-case RFU is equal to 0.22 mHz/s, whereas, a maximum uncertainty of 0.15 mHz/s is noticed at 50 Hz.

TABLE III  
WORST-CASE TOTAL VECTOR ERRORS AS FUNCTION OF CHARACTERIZED SYSTEM UNCERTAINTIES

Source	Uncertainty
magnitude	$12 \mu\text{V}$
phase angle	$0.8 \mu\text{rad}$
Range	TVE [%]
fundamental [45, 55] Hz	$3.56 \cdot 10^{-4}$
disturbance [5, 3000] Hz	$4.02 \cdot 10^{-3}$




Fig. 11. TVE as function of frequency in the range provided for the fundamental component, i.e. from 45 to 55 Hz.

### E. Total Vector Error

Once characterized the possible sources of uncertainty, we associate a worst-case TVE to the reference values provided by the validation system, by considering a conservative error range of plus/minus three times the standard deviation on both synchrophasor magnitude and phase. In Table III, we assess the worst-case TVE as function of the fundamental frequency. For this analysis, we consider a three-phase waveform in steady-state test conditions: we set the fundamental amplitude and initial phase equal to their nominal values, 9 V and 0 rad, respectively, while we vary the fundamental frequency from 45 to 55 Hz, with an incremental step of 1 Hz. As shown in Fig. 11, the worst-case TVE does not exceed  $5 \times 10^{-4}\%$ .

In the IEEE Std compliance verification, several test conditions require the validation system to generate multi-tone waveforms, i.e. consisting not only of a fundamental component, but also of one or more interfering components. In this sense, it is worth characterizing the system performance in the entire spectral bandwidth that can be interested by harmonic or interharmonic disturbances. The upper and lower graphs in Fig. 12 represent the worst-case TVE measured in the range [5, 25] and [75, 3000] Hz, respectively. In order to provide a term of comparison, in both the graphs we include also the TVE associated to the nearest extreme of the fundamental frequency bandwidth [45, 55] Hz. In the upper graph, we observe a degradation of the estimation accuracy due to the fact that lower frequency corresponds to lower number of periods in a given observation interval, and the fitting algorithm accuracy degrades up to a worst-case TVE in the order of  $5 \times 10^{-3}\%$ . As further discussed in [33], the performance could be easily




Fig. 12. TVE as function of frequency in the range provided for harmonic and interharmonic components, i.e. from 5 to 25 Hz (top) and from 75 to 3000 Hz (bottom).

enhanced by increasing the observation interval length or the sampling frequency, but we prefer to keep the same experimental configuration throughout the entire paper for the sake of congruency. In the lower graph of Fig. 12, the TVE is rather stable around  $2 \times 10^{-4}\%$ , i.e. the same accuracy level measured at the nominal frequency of 50 Hz. In the considered range, only at 75 Hz, a reduced performance degradation is noticed, with the worst-case TVE not exceeding  $5 \times 10^{-4}\%$ .

This analysis enables us to define a sort of frequency response of the proposed validation system. The experimental results confirm that it guarantees a noticeable level of estimation accuracy not only in the range associated to the fundamental component, but also in the entire spectral bandwidth associated to possible harmonic and interharmonic disturbances.

#### F. Stability issues

In the presence of repeated validations, an aspect to be considered is the estimation accuracy stability. Some uncertainty sources might introduce uncompensated contributions and thus produce erroneous estimates of the reference magnitude and phase. In particular, we focus on two synchronization issues: first, the atomic clock jitter increases the phase noise; second, the synchronization delay between generation and acquisition stages results in an imprecise definition of the reference initial phase. In the following paragraphs, we consider each source individually and discuss their effect on the validation results.

*a) Timing uncertainty:* The internal timing reference is provided by the rubidium atomic clock, disciplined by the GPS receiver. This hardware configuration enables us to simulta-




Fig. 13. Time deviation between the PPS signal provided to the PXI (PXi-PPS) and the PPS signal directly derived from UTC-CH (UTC-CH). Over an observation interval of two days, the standard deviation is lower than 12 ns, corresponding to a phase uncertainty of  $4 \mu\text{rad}$  at 50 Hz.

neously reduce both short- and long-term variability. On one side, the GPS receiver provides a PPS signal, characterized by a noticeable long-term stability, and guarantees the alignment with respect to UTC. On the other side, the rubidium atomic clock provides a 10 MHz time-base signal, with reduced short-term variability, that can be used to synchronize all the modules connected to the PXI chassis.

It is worth mentioning that the rubidium atomic clock derives the time-base signal directly from the PPS signal received from the GPS receiver. Thus, if we consider observation interval lengths not lower than 1 s, we can assume that the two signals are perfectly synchronized and locked in phase.

In this context, we provide a quantitative assessment of the performance enhancement guaranteed by the proposed configuration. First, we evaluate the long-term stability of the PPS signal. At METAS laboratories, we compare the PPS signal provided to the PXI with the PPS signal directly derived from UTC-CH. For this analysis, we employ the SR620 counter in time interval modality with an accuracy of 100 ps [39]: the PPS derived from UTC-CH starts the counter, while the PPS routed out by the PXI stops the counter. Fig. 13 presents the time deviation measured over an observation interval of 48 hours. We notice an average deviation in the order of hundreds ns, that represents a systematic contribution due to the length of the antenna cable (25 m) and can be compensated. Conversely, the standard deviation constitutes the actual contribution to the overall phase uncertainty. Considering a fundamental frequency of 50 Hz, the PPS uncertainty not larger than 12 ns corresponds to an estimation error on the synchrophasor phase of  $4 \mu\text{rad}$ .

Then, we assess the short-term stability of the 10 MHz time-base signal. At METAS laboratories, we measure the phase noise as function of the frequency offset with respect to the signal carrier frequency. In Fig. 14 we compare three different configurations: the first one consists of the PXI in free-running mode (blue circles), in the second one the PXI time-base is disciplined by the GPS receiver only (red crosses), the third one considers the proposed hardware configuration, with the rubidium atomic clock, disciplined by the GPS receiver (green squares). It is interesting to observe how the employment of




Fig. 14. Phase noise obtained with three different configurations: free-running PXI (circles), PXI disciplined by GPS receiver only (crosses), PXI disciplined by atomic clock and GPS receiver (squares). The last one guarantees a significant phase noise reduction over the considered frequency range.




Fig. 15. Initial phase displacement due to imprecise synchronization between generation and acquisition stage. In 1, we evaluate the uncertainty due to low-pass filter and acquisition stages. In 2, we determine the uncertainty due also to generation stage. The subtraction provides the single DAC contribution.

the GPS receiver only produces a reduced enhancement in the long-term stability. Conversely, the rubidium atomic clock guarantees a reduction of the phase noise by almost 30 dBc/Hz in the entire considered range.

Integrating the phase noise curve between 1 Hz to 20 MHz, we can also calculate the equivalent RMS phase jitter affecting the 10 MHz time-base signal. In the proposed hardware configuration, the employment of the rubidium atomic clock enables us to limit the jitter in the order of 1 ps, that corresponds to a phase uncertainty in the order of hundreds prad, thus negligible if compared with the PPS contribution.

*b) Synchronization uncertainty:* Within the proposed architecture, an imprecise internal synchronization of the hardware modules might be translated into a phase discrepancy between generated and acquired waveforms. We characterize the variability of this phenomenon by means of a two-step processing technique, inspired by a METAS procedure [11].

Fig. 15 provides a graphical representation of the proposed technique. In particular, the block diagram consists of two

parallel processing schemes. The upper one is related to the phase uncertainty of the acquisition stage only, whereas the lower one accounts for both generation and acquisition stage. From their subtraction, we estimate the initial phase contribution related to the generation stage only.

In the upper scheme, we derive from the 10 MHz time-base a square logic waveform, i.e. a transistor–transistor logic (TTL) signal with a duty cycle of 50%, with a given fundamental frequency  $f$ . In the following, this signal is referred to as sub-PPS (sPPS), as it is perfectly locked to the PPS signal provided by the GPS antenna. Then, we apply an analog passive low-pass filter with a cut-off frequency of nearly 725 Hz (the filter consists of a resistor of 10 k $\Omega$  and a capacitor of 0.022  $\mu$ F). In this way, even though the filtering stage introduces a systematic phase contribution, it limits the sPPS spectral bandwidth. Thus, we can acquire the filtered waveform without noticeable aliasing. For this analysis, we adopt a sampling frequency of 25 kHz with an experiment duration of 5 s, we trigger the ADC with the sPPS itself. We divide the acquired time-series into 200 observation intervals of 1 s, partially overlapped in order to reproduce a reporting rate of 50 fps. First, we remove the mean value in order to mitigate the spectral contributions caused by DC and low frequency. Then, we estimate the initial phase of the fundamental component by means of the eIpDFT algorithm. By repeating this analysis on each observation interval, we are able to determine the statistical distribution of the sPPS initial phase, in terms of mean and standard deviation, and thus characterize the uncertainty contribution due to low-pass filtering (LP) and acquisition (ADC) stages,  $\varphi_0^{LP+ADC}$ .

In the lower scheme, we employ the validation system to generate a sinusoidal waveform  $s$  in steady-state test conditions, with the same fundamental frequency  $f$  as in the upper scheme. For this analysis, amplitude and initial phase are set equal to 9 V and 0 rad, respectively. Then, we apply the same analog low-pass filter, and we trigger the ADC with the PPS signal provided by the GPS antenna. In this sense, the uncertainty on the trigger event is comparable to the one of the upper scheme, as sPPS and PPS are locked by construction. As in the upper scheme, the acquired time-series is divided into 200 observation intervals of 1 s, with a reporting rate of 50 fps. We use the eIpDFT algorithm to estimate the initial phase in each observation interval, and thus derive its statistical distribution in terms of mean and standard deviation. In this way, the lower scheme accounts for the uncertainty contribution due to generation (DAC), low-pass filtering (LP), and acquisition (ADC) stages,  $\varphi_0^{DAC+LP+ADC}$ .

Finally, we compute the difference between lower and upper scheme estimates. The resulting distribution accounts only for the generation uncertainty  $\varphi_0^{DAC}$ . Indeed, the contributions due to low-pass filtering and acquisition are perfectly equivalent in upper and lower schemes, and the corresponding synchronization signals (sPPS and PPS) are directly derived by the same timing reference.

Fig. 16 represents the time-domain trend of sPPS and  $s$ , in blue and red line, respectively, when the fundamental frequency is set equal to 50 Hz. It is interesting to observe how the LP filtering stage has limited the actual bandwidth




Fig. 16. Detail of the signals sPPS (blue) and s (red), as acquired in the upper and lower scheme of the routine for initial phase characterization. The difference between the corresponding initial phases accounts for the internal synchronization delay between generation and acquisition stages.




Fig. 17. Detail for the DFT module of the signals sPPS (blue) and s (red), expressed in pu. Nevertheless, the adopted frequency resolution allows for minimizing spectral leakage effects.

of the TTL signal, characterized by smoothed transitions and damped oscillations. On first approximation, the signals seem synchronized as their zero-crossing locations are nearly coincident. Nevertheless, the proposed analysis is intended to determine the non-negligible delay introduced by the internal synchronization between DAC and ADC stages.

In Fig. 17, we present the DFT of the acquired sPPS and s. For the sake of clarity, the observed bandwidth is limited to 300 Hz and the DFT coefficients have been normalized and expressed in pu. Given a frequency resolution of 1 Hz, it is reasonable to assume that the leakage contributions are almost negligible. Also the odd harmonic terms included in the sPPS spectrum do not introduce significant distortions in the fundamental tone estimation.

We repeat this analysis varying the frequency of sPPS and s waveforms within the range [10, 500] Hz. In particular, we consider frequency values that are integer dividers of 10 MHz. In fact, the peculiar configuration of the PXI internal clock requires this constraint to be satisfied, in order to guarantee sufficient stability of the sPPS waveform period. In Fig. 18, we represent the standard deviation of  $\varphi_0^{DAC}$  as function of sPPS frequency. It is interesting to observe how the synchronization




Fig. 18. Initial phase uncertainty due to DAC initial phase contribution as function of sPPS and s frequency.

uncertainty ranges from 1.1 to 4.6  $\mu\text{rad}$ , i.e. it is comparable with the timing uncertainty.

## V. VALIDATION ACCURACY IN IEEE STD TESTS

In the previous Section, the metrological characterization has involved only steady-state test conditions, in order to guarantee a fair comparison with the estimates provided by the high-accuracy hardware instrumentation. Nevertheless, it is reasonable to assume that the validation system provides similar results in any other test conditions, since the generation, acquisition and fitting procedure keeps unaltered.

In this Section, we characterize the system performance in all the test conditions provided by the IEEE Std. Since the reference values for synchrophasor magnitude, phase, frequency and ROCOF cannot be measured through multimeter or counter (in the dynamic tests), they are set equal to the parameter values set by the user in the generation stage.

Following the same procedure previously described in Section IV, we define the parameters of signal model (1) in order to reproduce the desired test condition, we acquire a time-series of 5 s, and divide it into 248 consecutive observation intervals of 60 ms, with a reporting rate of 50 fps. Generation and acquisition stage adopt a sampling frequency of 100 and 25 kHz, respectively. Then, we evaluate the synchrophasor magnitude and phase uncertainty, and compute the corresponding worst-case TVE, FE and RFE, as reported in Table IV as function of the test condition.

We divide the table into three parts, corresponding to three different classes of test conditions. The upper part accounts for nominal steady-state conditions, with fundamental amplitude, frequency and initial phase set to 9 V, 50 Hz and 0 rad, respectively. In this case, TVE is in the order of  $2 \cdot 10^{-4}\%$  and FE does not exceed 2.3  $\mu\text{Hz}$ .

In the middle part, we consider the M-class requirements for the steady-state compliance verification. First, we evaluate the calibration accuracy as function of the fundamental tone parameters. For this analysis, we vary the fundamental amplitude from 10 to 120% of its nominal value, and the fundamental frequency from 45 to 55 Hz. In these tests, TVE and FE are limited to  $1.85 \cdot 10^{-3}\%$  and 20.5  $\mu\text{Hz}$ , respectively.

Then, we consider the effect of harmonic and inter-harmonic distortion. In particular, we reproduce an additive interfering

tone, whose amplitude is equal to 10% of fundamental amplitude. In these tests, we obtain a maximum TVE of  $4.05 \cdot 10^{-4}\%$  and a maximum FE of  $4.2 \mu\text{Hz}$ .

The lower part presents the performance of the proposed system in the M-class requirements for the dynamic compliance verification. In the measurement bandwidth test, we apply a simultaneous modulation of amplitude (AM) and phase (PM), with a modulation frequency of 5 Hz and a modulation depth of 0.9 pu and 0.1 rad, respectively. For the sake of completeness, we also report the accuracy of AM and PM applied separately. The maximum TVE is around  $3.6 \cdot 10^{-2}\%$ , and the maximum FE does not exceed 1.35 mHz.

For the frequency ramp test, we reproduce a test waveform of 10 s, and vary the fundamental frequency between 45 to 55 Hz with a linear rate of 1 Hz/s. In this test, the worst-case performance corresponds to a maximum TVE of  $9.2 \cdot 10^{-2}\%$  and a maximum FE of 4.9 mHz.

Finally, we evaluate the performance under step changes in fundamental amplitude and phase. In particular, we consider variations of  $\pm 0.9$  pu and  $\pm \pi/10$ , in terms of amplitude and phase, respectively. In this case, we obtain a maximum TVE of  $4.24 \cdot 10^{-4}\%$  and a maximum FE of  $7.2 \mu\text{Hz}$ .

The step change tests are intended to evaluate the PMU response time and reporting latency. In more detail, the response time is defined as the time interval between the instants when the PMU measurement accuracy exceeds and respects again given limit ( $\text{TVE} \leq 1\%$ ,  $\text{FE} \leq 5$  mHz). The reporting latency, instead, is the maximum time interval between the time stamp of the PMU measurement, and the time when the data becomes available at the PMU output. In this regard, the IEEE Std requires to quantify response time and reporting latency with an accuracy not lower than 2 ms and  $100 \mu\text{s}$ , respectively.

As regards the response time, the proposed system can be easily employed to carry out an interleaved analysis, where the waveform parameters keep constant and the only step occurrence time is varied with a resolution given by the adopted sampling rate, i.e.  $40 \mu\text{s}$  at 25 kHz. As regards the reporting latency, instead, the PDC integrated within the validation system enables us to collect the measurement data packets coming from the PMU under test and align them based on their time-stamp [35]. In order to guarantee the required level of accuracy, as soon as the waveform generation begins, we count the clock ticks elapsed until each packet arrives. In this way, we are able to characterize the reporting latency with the resolution of the internal time-base, i.e. 100 ns.

## VI. OFF-STANDARD TEST CONDITIONS

The proposed validation system is specifically designed for the characterization of PMU operating in DNs. To this end, in addition to the canonical tests provided by the IEEE Std, the proposed system is also capable of reproducing user-defined test conditions, that better approximate typical DN operating conditions. In this sense, a single constraint has to be satisfied: the user-defined signal model has to be a special case of (1).

In this Section, we focus on two specific cases, namely a voltage unbalanced three-phase waveform and a load inrush event, which typically can occur in distribution networks characterized by fast dynamics and high volatility of RESs.

TABLE IV  
CALIBRATION PERFORMANCE IN IEEE STD. C37.118.1 TESTS

Test	TVE [%]	FE [Hz]	RFE [Hz/s]
nominal	$2.03 \cdot 10^{-4}$	$2.29 \cdot 10^{-6}$	$2.29 \cdot 10^{-4}$
signal amplitude	$1.84 \cdot 10^{-3}$	$2.02 \cdot 10^{-5}$	$2.02 \cdot 10^{-3}$
signal frequency	$3.56 \cdot 10^{-4}$	$4.31 \cdot 10^{-6}$	$4.31 \cdot 10^{-4}$
harmonic dist.	$1.74 \cdot 10^{-4}$	$4.19 \cdot 10^{-6}$	$4.19 \cdot 10^{-4}$
out-of-band dist.	$4.02 \cdot 10^{-4}$	$1.50 \cdot 10^{-6}$	$1.50 \cdot 10^{-4}$
meas. bandwidth	$3.57 \cdot 10^{-2}$	$1.34 \cdot 10^{-3}$	$1.34 \cdot 10^{-1}$
ampl. modulation	$2.53 \cdot 10^{-5}$	$6.40 \cdot 10^{-2}$	$6.40 \cdot 10^{-3}$
phase modulation	$2.52 \cdot 10^{-2}$	$1.34 \cdot 10^{-3}$	$1.34 \cdot 10^{-1}$
frequency ramp	$9.17 \cdot 10^{-2}$	$4.86 \cdot 10^{-3}$	$4.86 \cdot 10^{-1}$
step change	$4.24 \cdot 10^{-4}$	$7.19 \cdot 10^{-6}$	$7.19 \cdot 10^{-4}$




Fig. 19. Detail of three-phase unbalanced waveform, compliant with the limits provided by EN 50160. Inverse and homopolar sequence energy correspond to nearly 2 and 0.0003% of the direct sequence energy, respectively.

*Voltage unbalance:* The voltage characteristics of European public distribution systems are regulated by EN 50160. In terms of voltage unbalance, EN 50160 considers ratio between the average RMS value of negative and positive phase sequence, computed over an observation interval of 10 min. Under normal operating conditions, during a week, this ratio shall not exceed 2%. Accordingly, we reproduce a three-phase waveform, whose single phases are defined as follows:

$$\begin{aligned}
 x_A(t) &= 9.18 \cdot \cos(2\pi 50t + 0) \\
 x_B(t) &= 9.00 \cdot \cos(2\pi 50t + 2.1287) \\
 x_C(t) &= 8.82 \cdot \cos(2\pi 50t - 2.0951)
 \end{aligned} \tag{5}$$

in order to reproduce a voltage unbalance of 2% (see Fig. 19).

*Load inrush:* As shown in Fig. 20, a load inrush event produces a current waveform with a rapidly increasing amplitude, followed by an exponentially-decaying trend. The test signal model is defined as follows:

$$\begin{aligned}
 x(t) &= A \cdot \sin(2\pi ft + \varphi_0) + \eta \\
 \eta(t) &= \left( \frac{A_T}{1 + e^{-k(t-T_T)}} \right) \cdot e^{-\frac{t-T_T}{\tau}} \sin(2\pi ft + \varphi)
 \end{aligned} \tag{6}$$

where the current inrush event is modelled by the additive term  $\eta(t)$ . The parameters  $A_T$  and  $T_T$  determine the transient amplitude and occurrence time, respectively, whereas  $\tau$  is the time-constant of the exponential decay. For this analysis, the




Fig. 20. Detail of a current in-rush event, as reproduced by the proposed PMU calibrator.

TABLE V  
CALIBRATION PERFORMANCE IN OFF-STANDARD TESTS

Test	TVE [%]	FE [Hz]	RFE [Hz/s]
unbalanced	$3.69 \cdot 10^{-4}$	$3.80 \cdot 10^{-6}$	$3.80 \cdot 10^{-4}$
inrush	$2.53 \cdot 10^{-1}$	$2.19 \cdot 10^{-5}$	$2.19 \cdot 10^{-3}$

fundamental amplitude, frequency and initial phase are set equal to 1 p.u., 50 Hz and 0 rad, respectively. The current inrush occurs at  $T_T = 0.495$  s with  $k = 10000$ , and we set  $A_T$ ,  $\tau$  and  $\phi$  equal to 6 p.u., 0.087 and 1.53 rad, respectively.

In Table V, we report the performance in the considered off-standard conditions, in terms of TVE, FE and RFE. In a more conservative approach, for each considered performance index, we report only the maximum value observed on the three phases. In the case of voltage unbalanced waveform, we obtain an accuracy level comparable with the nominal steady-state conditions, with a maximum TVE of  $3.70 \cdot 10^{-4}\%$  and a maximum FE of  $3.80 \mu\text{Hz}$ . On the other side, also in the presence of a severe transient event, like a current inrush, the PMU calibrator is capable of providing accurate estimates, with a maximum TVE in the order of 0.25% and a maximum FE not exceeding  $22 \mu\text{Hz}$ .

The proposed system enables us to thoroughly characterize the metrological performance of the PMUs under test. On one side, it performs the entire steady-state and dynamic compliance verification tests, according to the IEEE Std requirements. On the other side, the system is also capable of reproducing user-defined test conditions without comparable performance in terms of estimation accuracy. This additional feature could be useful to compare the response of different smart metering devices (such as power meters) to transient events or other off-standard operating conditions.

## VII. CONCLUSION

This paper presents the metrological characterization of a high-accuracy validation system for PMUs operating in distribution networks. First of all, we provide an overview of the existing PMU calibrators and deduce the motivations of this work: a significant enhancement of the accuracy of the

reference values and a rigorous assessment of the uncertainty contributions inherent in modern validation systems.

Then, we described the system hardware and software architecture, and perform a thorough metrological characterization of the test waveform accuracy. First, we evaluate the power quality of the generated test waveforms in terms of SINAD, THD and VUF. Then, we characterize the magnitude, phase and frequency uncertainty by comparing the estimates of the proposed system against the reference values provided by high-accuracy hardware instrumentation. Based on these results, we derive the maximum TVE as function of frequency in the entire spectral bandwidth involved in synchrophasor measurements, i.e. [5, 3000] Hz. In nominal conditions, at 50 Hz, TVE is in the order of  $2 \cdot 10^{-4}\%$ , whereas the worst performance is obtained at 5 Hz, when TVE does not exceed  $5 \cdot 10^{-3}\%$ . Finally, we discuss the stability of the estimation accuracy in the presence of repeated experiments. In this context, we evaluate the uncertainty contributions related to the timing reference provided by the atomic clock ( $4 \mu\text{rad}$ ) and the internal synchronization between generation and acquisition stage ( $4.6 \mu\text{rad}$ ).

As the hardware instrumentation accuracy is guaranteed only in stationary non-distorted conditions, the metrological characterization considers only steady-state test waveforms. Accordingly, the performance evaluation in the IEEE Std tests is performed taking as reference the parameter values set by the user in the generation stage. In the steady-state compliance tests, worst-case TVE and FE are limited to  $1.85 \cdot 10^{-3}\%$  and  $20.5 \mu\text{Hz}$ , respectively. In the dynamic compliance tests, instead, we obtain a TVE and FE not larger than  $9.2 \cdot 10^{-2}\%$  and  $4.9 \text{ mHz}$ , respectively.

The proposed system is also capable of reproducing user-defined test conditions, that better approximate ADNs scenario. In particular, we consider a voltage unbalanced waveform and a load inrush event. This additional feature enables us to compare the response of PMUs or other smart metering device (e.g. power quality meters) to transient events or other off-standard operating conditions.

## ACKNOWLEDGMENT

The research leading to the results described in this paper is part of the European Metrology Research Program (EMRP), which is jointly funded by the EMRP participating countries within EURAMET and the European Union.

## REFERENCES

- [1] M. Kezunovic, J. D. McCalley and T. J. Overbye, "Smart Grids and Beyond: Achieving the Full Potential of Electricity Systems," in Proceedings of the IEEE, vol. 100, no. Special Centennial Issue, pp. 1329-1341, May 13 2012.
- [2] A. Monti, C. Muscas, F. Ponci, "Phasor Measurement Units and Wide Area Monitoring Systems," Academic Press, 2016.
- [3] "IEEE Standard for Synchrophasor Measurements for Power Systems," IEEE Std. C37.118.1-2011, Dec. 2011.
- [4] "IEEE Standard for Synchrophasors Measurement for Power Systems, Amendment 1: Modification of Selected Performance Requirements," IEEE C37.118.1a-2014, Apr. 2014.
- [5] C. Muscas, M. Pau, P. A. Pegoraro and S. Sulis, "Uncertainty of Voltage Profile in PMU-Based Distribution System State Estimation," in IEEE Transactions on Instrumentation and Measurement, vol. 65, no. 5, pp. 988-998, May 2016.

- [6] M. Chakir, I. Kamwa and H. Le Huy, "Extended C37.118.1 PMU algorithms for joint tracking of fundamental and harmonic phasors in stressed power systems and microgrids", IEEE Trans. Power Del., vol. 29, no. 3, pp. 1465-1480, 2014.
- [7] P. Romano, "DFT-based Synchrophasor Estimation Algorithms and their Integration in Advanced Phasor Measurement Units for the Real-time Monitoring of Active Distribution Networks," PhD Thesis, EPFL, Lausanne, 2016 [online] Available: <http://desl-pwrs.epfl.ch/cms/site/desl/lang/en/theses>
- [8] A. Borghetti, C. A. Nucci, M. Paolone, G. Ciappi and A. Solari, "Synchronized Phasors Monitoring During the Islanding Maneuver of an Active Distribution Network," in IEEE Transactions on Smart Grid, vol. 2, no. 1, pp. 82-91, March 2011.
- [9] P. Gupta, R. S. Bhatia and D. K. Jain, "Active ROCOF Relay for Islanding Detection," in IEEE Transactions on Power Delivery, vol. 32, no. 1, pp. 420-429, Feb. 2017.
- [10] G. Barchi, D. Macii and D. Petri, "Synchrophasor Estimators Accuracy: A Comparative Analysis," in IEEE Transactions on Instrumentation and Measurement, vol. 62, no. 5, pp. 963-973, May 2013.
- [11] J. P. Braun and S. Siegenthaler, "The Metrological Characterization of PMUs," Workshop on Synchrophasor Estimation Processes for Phasor Measurement Units, Lausanne, CH, Dec. 2014 [online] Available: <http://desl-pwrs.epfl.ch/workshop>.
- [12] "International Vocabulary of Metrology – Basic and General Concepts and Associated Terms (VIM 3rd edition)," Joint Committee for Guides in Metrology (JCGM), 2012.
- [13] D. Colangelo, L. Zanni, M. Pignati, P. Romano, M. Paolone, J. P. Braun and L. G. Bernier, "Architecture and Characterization of a Calibrator for PMUs Operating in Power Distribution Systems," PowerTech, 2015 IEEE Eindhoven, Eindhoven, 2015, pp. 1-6.
- [14] G. Frigo, C. Narduzzi, D. Colangelo, M. Pignati and M. Paolone, "Definition and assessment of reference values for PMU calibration in static and transient conditions," 2016 IEEE International Workshop on Applied Measurements for Power Systems (AMPS), Aachen, 2016, pp. 1-6.
- [15] Y.H. Tang, G.N. Stenbakken and A. Goldstein, "Calibration of Phasor Measurement Unit at NIST," in IEEE Transactions on Instrumentation and Measurement, vol. 62, no. 6, pp. 1417-1422, June 2013.
- [16] J. P. Braun and C. Mester, "Reference grade calibrator for the testing of the dynamic behavior of phasor measurement units," Precision Electromagnetic Measurements (CPEM), 2012 Conference on, Washington, DC, 2012, pp. 410-411.
- [17] D. Colangelo, D. Hoogenboom, E. Dierikx, G. Rietveld and G. Frigo, "Metrological characterization of a PMU calibrator in the 25 Hz to 3 kHz range," 2017 IEEE Manchester PowerTech, Manchester, 2017, pp. 1-6.
- [18] B. Trinchera, D. Serazio and U. Pogliano, "Asynchronous Phase Comparator for Characterization of Devices and PMU Calibrator," Precision Electromagnetic Measurements (CPEM), 2016 Conference on, Ottawa, ON, 2016, pp. 1-2.
- [19] R. Garcia-Valle, G. Yang, K.E. Martin, A.H. Nielsen, and J. Østergaard, "DTU PMU Laboratory Development – Testing and Validation," 2010 IEEE PES Innovative Smart Grid Technologies Conference Europe (ISGT Europe), Gothenburg, 2010, pp. 1-6.
- [20] J.O. Fernandez, "The Virginia Tech Calibration System," Master Thesis, Virginia Polytechnic Institute and State University, Blacksburg, 2011 [online] Available: <https://vtechworks.lib.vt.edu/handle/10919/32669>
- [21] C. Qian and M. Kezunovic, "Synchrophasor reference algorithm for PMU Calibration System," 2016 IEEE/PES Transmission and Distribution Conference and Exposition (T&D), Dallas, TX, 2016, pp. 1-5.
- [22] 6135A/PMUCAL Phasor Measurement Unit Calibration System, Fluke Corporation, Oct. 2013 [online] Available: <http://us.flukecal.com/products/electrical-calibration/electrical-calibrators/>
- [23] Q. Guo, F. Chen, R. Piacentini, "Virtual-Instrumentation-Based PMU Calibrator for IEEE C37.118.1-2011 Compliance Testing," in 2014 CIGRE Grid of the Future Symposium, Houston, TX, 2014, [online] Available: <http://cigre.wpengine.com/gotf-2014-papers/>
- [24] 8-Slot, Universal AC PXI Chassis, National Instruments, Sep. 2014, [online] Available: <http://www.ni.com/it-it/support/model.pxi-1042.html>
- [25] Rubidium Frequency Standard - FS725, Stanford Research Systems, Ver 1.3, Dec. 2015, <http://www.thinksrs.com/products/FS725.htm>
- [26] GPS Clock for Computers (PCI/PCI-X Bus) - GPS169PCI, Meinberg Funkhrehn GmbH & Co. KG, Apr. 2011, [online] Available: <https://www.meinbergglobal.com/english/archive/gps169pci.htm>
- [27] IEEE Guide for Synchronization, Calibration, Testing, and Installation of Phasor Measurement Units (PMUs) for Power System Protection and Control, IEEE Std. C37.242TM-2013.
- [28] IEC Standard 61869-6 Instrument transformers - Part 6: Additional general requirements for low-power instrument transformers
- [29] G. Crotti, D. Gallo, D. Giordano, C. Landi and M. Luiso, "Medium Voltage Divider Coupled With an Analog Optical Transmission System," in IEEE Transactions on Instrumentation and Measurement, vol. 63, no. 10, pp. 2349-2357, Oct. 2014.
- [30] M. Pignati et al. "Real-time state estimation of the EPFL-campus medium voltage grid by using PMUs," presented at the IEEE Power and Energy Society Conference (ISGT), 2015, 17-20 February 2015.
- [31] G. Crotti, D. Gallo, D. Giordano, C. Landi and M. Luiso, "Industrial Comparator for Smart Grid Sensor Calibration," in IEEE Sensors Journal, vol. 17, no. 23, pp. 7784-7793, Dec.1, 1 2017.
- [32] E. Mohns et al., "Calibration of Commercial Test Sets for Non-Conventional Instrument Transformers," 2017 IEEE International Workshop on Applied Measurements for Power Systems (AMPS), Liverpool, 2017, pp. 1-6.
- [33] G. Frigo, D. Colangelo, A. Derviškić, M. Pignati, C. Narduzzi and M. Paolone, "Definition of Accurate Reference Synchrophasors for Static and Dynamic Characterization of PMUs," in IEEE Transactions on Instrumentation and Measurement, vol. PP, no.99, pp.1-14
- [34] P. Romano and M. Paolone, "Enhanced Interpolated-DFT for Synchrophasor Estimation in FPGAs: Theory, Implementation, and Validation of a PMU Prototype," in IEEE Transactions on Instrumentation and Measurement, vol. 63, no. 12, pp. 2824-2836, Dec. 2014.
- [35] A. Derviškić, P. Romano, M. Pignati and M. Paolone. "Architecture and Experimental Validation of a Low-Latency Phasor Data Concentrator," in IEEE Transactions on Smart Grids, vol. -, num. -, p. 1-10, 2017.
- [36] H. Markiewicz and A. Klajn, "Standard EN 50160 - Voltage Characteristics in Public Distribution Systems," Technical Report: Leonardo Power Quality Initiative (LPQI), The European Commission, Wrocław University of Technology, July 2004.
- [37] 3458A Multimeter, Keysight Technologies, Ver. 7, Aug. 2014, [online] Available: <http://literature.cdn.keysight.com/litweb/pdf/03458-90014.pdf>
- [38] R. Lapuh, B. Voljc and M. Lindic, "Evaluation of Agilent 3458A Time Jitter Performance," in IEEE Transactions on Instrumentation and Measurement, vol. 64, no. 6, pp. 1331-1335, June 2015.
- [39] Universal Time Interval Counter - SR620, Stanford Research Systems, Ver 2.7, Feb. 2006, <http://www.thinksrs.com/products/SR620.htm>